



10' GROUND WITH 30' AERIAL, BACK TO BACK EASEMENT

AN UNOBSTRUCTED AERIAL EASEMENT TEN (10) FEET WIDE EXTENDING UPWARD BEGINS AT A HEIGHT OF SIXTEEN (16) FEET ABOVE THE GROUND ADJOINING AND ON BOTH SIDES OF THE 10 FOOT WIDE EASEMENT.

10 FOOT WIDE EASEMENT IS DESIGNED FOR OVERHEAD POWER LINES ONLY. FOR URD IT WILL NOT PROVIDE ADAQUATE CLEARANCE FOR PADMOUNTED EQUIPMENT. SEE STANDARDS 05-890 AND 05-900 FOR EASEMENT DESIGNED FOR URD.

BACK TO BACK EASEMENTS

- ① POLES TO BE LOCATED NORTH OF EAST-WEST PROPERTY LINES AND EAST OF NORTH-SOUTH PROPERTY LINES.
- ② WHEN THE PROPERTY LINE IS NOT INSIDE THE EASEMENT THE POLE LINE MAY BE LOCATED ON THE CENTER LINE OF THE EASEMENT.

DISTRIBUTION STANDARD
05-925

(FOR OVERHEAD POWER LINE ONLY)

10' GROUND WITH 30' AERIAL, BACK TO BACK CNP EXCLUSIVE EASEMENT
CenterPoint Energy
HOUSTON, TEXAS

NO.	DATE	REVISION	BY	CH	APP.	DRAWN	CHECKED	APPROVED	SECTION	SUB-SECTION	SHEET	OF	SHEETS
1	7-8-19	CHANGE THE GAS LINE DEPTH FROM 30" TO 36"	SCM	JCD	MC	7-18-07	7-19-07	7-23-07	05	925	1	1	1
											004	235	30