

- 1) SIDE LOT EASEMENTS WILL REQUIRE THE SAME DIMENSIONS AND SPACE ALLOCATION AS EASEMENT ON REAR LOT LINE WHETHER IT BE CENTERED ON, ADJACENT TO, SIDE LOT LINE.
- 2 CUSTOMER'S SERVICE LATERALS MUST HAVE A MINIMUM OF 24" EARTH COVER AND MUST CLEAR ALL OTHER UTILITIES BY 4" OR MORE. PER NESC 352D
- IN TYPICAL EAST-WEST AND NORTH-SOUTH EASEMENTS, THE ARRANGEMENT WILL BE GENERALLY AS SHOWN. IN CURVILINEAR DEVELOPMENT PATTERNS, STANDARD ALLOCATED LOCATIONS IN REFERENCE TO THE NORTH AND EAST SIDE WILL BE AT A CONVENIENT STARTING PLACE AND WILL USUALLY BE DECIDED BY MUTUAL AGREEMENT. CROSSOVERS WILL NOT BE MADE ALONG THE EASEMENT.
- THE SECONDARY PEDESTAL SHOULD BE INSTALLED 90 DEGREES TO THE TRENCH.

| | | | | | | | | | HOUSTON, TEXAS | | | |
|-----|------|----------|--|-----|-------|------------------|----------|--------|----------------|----------------|-------------|----------|
| - 1 | 121 | Ø8-27-18 | REVISED NOTE 2 | SCM | l JCD | l _{TRS} | DRAWN | 1-6-98 | H. BOWLDEN | SECTION 3 | 31 ѕив-ѕест | ION 420 |
| - | لئے | | | _ | | | | 17.00 | | SHEET 1 | . of 1 | 1 SHEETS |
| | 11 1 | | REVISED PLACEMENT OF SECONDARY PEDESTAL & ADDED NOTE 4 | LRM | JCD | LHH | CHECKED | 1-7-98 | JAMES C. DAVIS | DRAWING NUMBER | | |
| | NO. | | REVISION | BY | CH | APP. | APPROVED | 1-7-98 | R.K. MURPHY | 004 | 269 | Ø3 |
| | | | | | | | | | | | | |

DISTRIBUTION STANDARD

31-420

RESIDENTIAL
EASEMENT DETAILS
(16' EASEMENT)

CenterPoint Energy